

# **Product Guide**



# PPAD-C-MB-EXT-DALI-ADDR

## Miniature Integration IP Presence Detector iLight DALI Network - SCMD2/4

### Overview




The PPAD-C-MB -EXT-DALI-ADDR is a combined passive infrared (PIR) motion sensor and photocell designed to be part of a iLight DALI Network - SCMD2/4.

Functioning as a presence detector, the unit returns occupancy data to the network.

The photocell provides a lux level measurement value to the network.

## **Features**

#### Sensor head



#### **PIR Sensor**

Detects movement within the unit's detection range, allowing load control in response to changes in occupancy.

#### IR Receiver

Receives control and programming commands from an IR (infrared) handset.

### **Light Level Sensor**

Measures the overall light level in the detection area


#### Status LEDs

The LED flashes **R**ed to indicate the following:

Walk Test LED active	when movement is detected
Valid setting received	<b>₩</b>

## **Detection diagram**

### Range



Area of high sensitivity	Area of lower sensitivity
mg. sensitivity	


Note: illustration shows an average of the walk across

### Walk across



Height	Range Diameter
7m	16m
2.8m	9m

### Walk towards



Height	Range Diameter
7m	10m
2.8m	5m

## **Installation PPAD-C-MB-EXT-DALI-ADDR**


#### **Choosing a Suitable Location**

The detector should be sited so that the occupants of the room fall inside the detection pattern shown previously, at a recommended ceiling height of 2.8m. Note that the lower the sensor is installed the smaller the detection range will be, subject to the parameters shown on the detection diagram.


- Avoid direct sunlight entering the sensor.
- Do not site within 1m of forced air heating or ventilation.
- Do not fix to a vibrating surface.
- Do not exceed maximum length of cable (300m) on 1.5mm<sup>2</sup> data bus.
- Do not exceed maximum bus loading (250mA).
- Do not exceed maximum of 8 sensors per DALI bus.

# **Mounting**

This product can be mounted using the provided thread and gasket as shown. A 32mm diameter hole cut-out will be required.



The PPAD-C-MB-EXT-DALI-ADDR IS supplied with 1m, 2 core 1.5mm<sup>2</sup> double insulated cable to connect to the iLight DALI Network - SCMD2/4. The device is designed to operate correctly polarity-free.



## Technical data

**Dimensions** See diagrams opposite

0.10kg Weight

Supply Voltage 9.5VDC-22.5VDC via DALI

**Supply Current** 8mA

-10°C to 35°C Temperature


Humidity 5 to 95% non-condensing


Material (casing) Flame retardant ABS and PC/ABS

Type Class 2

IP rating PPAD-C-MB-EXT-DALI-ADDR

IP65 (BS60598-1 2015 to 15 minutes)





Compliance



# Part numbers

Part number Description **Detector** 

PPAD-C-MB-EXT-DALI-ADDR Miniature IP integration presence detector

### **IMPORTANT NOTICE!**

This device should be installed by a qualified electrician in accordance with the latest edition of the IEE Wiring Regulations and any



**Cooper Lighting Solutions** 

Usk House, Lakeside Llantarnam Park, Cwmbran, NP44 3HD, UK

+44 (0)1633 838088 Tel: +44 (0)1633 867880 info@cooperlighting.co.uk www.cooperlighting.co.uk

Ref:9850-000699-00 Rev 01